

4-10-19

Hydrology Comments on Wall Permit 201400097

1. Include all property lines and the Public Utility Easement on a scaled site plan. The PUE is 7 feet wide, south of the north property line.
2. The retaining wall and the "if required" wall shown above the retaining wall should be located outside the PUE and ROW.
3. Tension mats should not extend into the PUE or ROW.
4. It is not clear if the proposed wall is the same height as shown on the approved grading plan. The site plan will help with this determination.
5. Show location of retaining wall on the scaled site plan.
6. Include a copy of the approved grading plan, Marvin Kortum 6-17-04 and 6-30-04, in the permit set or a revised grading plan.

If you would like to meet to discuss, please give me a call.

Curtis Cherne, P.E.

Hydrology, Planning Dept.

924-3986