



City of Albuquerque Stormwater Construction Site Inspection Report

General Information

ESC File No.	L23E022	Project Name:	Beehive Four Hills		
NPDES Id. No.	NMR1001RX	Location:	13450 Wenonah Ave. SE		
4/19/2021	Owner	Contractor			
Operator	Host Care, LLC.	S & J Ent.			
Contact name & title	Jerry Castillo	Jason Castillo			
e-mail	Castillofour@msn.com	jasoncastillo88@gmail.com			
Contact Phone #	505-884-6243				
COA Inspector	Thomas Evans	Start/End Time:	11:30 AM/12:00 PM		
Construction Phase:	infrastructure				
Type of Inspection:	Regular	Storm Event	Past Storm Event >0.25"	311/Complaint	Follow Up
Weather at time of inspection?	clear		Temperature:	~ 65	
Estimated date of last storm 0.25" or greater	2/22/2021				
Item Number	Deficiency/ Corrective Action				
1	No posting of permit				
2	Repair/replace silt fence along North perimeter				
3	Pick up waste along South perimeter				
4	Maintain BMPs for stabilization				
2.1	Discharge off site? (Y/N)	no			
4	Self Inspection Reports	Requested	Latest report Date:		

Notes:	Need to confirm the status of stabilization on the East half of the site. Provide latest self-inspection report.

City of Albuquerque Stormwater Inspector Signature and date:
Contact information: Thomas Evans (505-803-6215)
tevans@cabq.gov

Thomas Evans 04/21/2021