



City of Albuquerque Stormwater Construction Site Inspection Report

General Information

ESC File No.	L23E022	Project Name:	Beehive Four Hills		
NPDES Id. No.	NMR1001RX	Location:	13450 Wenonah Ave. SE		
9/9/2022	Owner	Contractor			
Operator	Host Care, LLC.	S & J Ent.			
Contact name & title	Jerry Castillo	Jason Castillo			
e-mail	Castillofour@msn.com	jasoncastillo88@gmail.com			
Contact Phone #	505-884-6243				
COA Inspector	Doug Hughes	Start/End Time:	3:10 PM		
Construction Phase:	idle/stabilization				
Type of Inspection:	Regular	Storm Event	Past Storm Event >0.25"	311/Complaint	Follow Up
Weather at time of inspection?		clear	Temperature: ~	88	
Estimated date of last storm 0.25" or greater		8/21/2022			
Item Number	Deficiency/ Corrective Action				
1	The stabilization on this site satisfies the final stabilization criteria CGP 2.2.14, even a couple of pad sites have been covered in gravel.				
2	The EPAs web site shows permit coverage expired. Please file the Notice of Termination (NOT) with the EPA.				
3	Future EPA permit coverage will not be required for the two remaining pad sites when they go to Building Permit because the entire "Common Plan of Development" is stabilized according to Google Earth street view dated 4/22.				
2.1	Discharge off site? (Y/N)	no			
4	Self Inspection Reports	Requested	Latest report Date:	n/a	

Notes:	

City of Albuquerque Stormwater Inspector Signature and date:
Contact information: Doug Hughes (505-924-3420)
jhughes@cabq.gov