

Olson, Greg

From: Rodriguez, Jason T.
Sent: Thursday, March 27, 2014 1:35 PM
To: Olson, Greg
Cc: Silva, David; david@riograndeengineering.com
Subject: beehive Homes
Attachments: DSCN1015.pdf; DSCN1011.pdf

Roy the contractor formed the wall face and poured the rapid road mix he also put wire in the patch and all the old concrete was removed so it's a pass. If you need any more contact me.

Thanks Jason

L23-D022
50-19
Connection to
4-Hills Channel
OK
3/27/14



