


ALL ACCESS ROADS AND FIRE LANES  
WILL ACCOMMODATE A 28' MINIMUM  
TRUCK TURNING RADIUS



SQFT: 10214 CONSTRUCTION TYPE: V-B  
 GPM: 1500 NUMBER OF HYDRANTS: 1  
 THESE CONSTRUCTION DOCUMENTS WERE REVIEWED AND APPROVED BY  
 THE ALBUQUERQUE FIRE MARSHAL'S OFFICE IN ACCORDANCE WITH CITY  
 ORDINANCE, THE INTERNATIONAL FIRE CODE, AND NFPA STANDARDS.  
 THIS PERMIT IS VALID FOR 180 DAYS. FINAL INSPECTION IS REQUIRED.



**KIDS ACADEMY**  
7800 SAGE RD SW

|                                                |  |      |             |                                  |
|------------------------------------------------|--|------|-------------|----------------------------------|
| No                                             |  | Date | Description | DESIGN DEVELOPMENT<br><br>ISSUE: |
|                                                |  |      |             |                                  |
|                                                |  |      |             |                                  |
|                                                |  |      |             |                                  |
|                                                |  |      |             |                                  |
|                                                |  |      |             |                                  |
| SHEET TITLE                                    |  |      |             | PROJECT NUMBER: IA 2389          |
| FIRE HYDRANT<br>LOCATION<br>AND ACCESS<br>PLAN |  |      |             | FILE:                            |
|                                                |  |      |             | DRAWN BY: DEC                    |
|                                                |  |      |             | CHECKED BY: FCA                  |
|                                                |  |      |             | DATE: 12-15-2020                 |
| SHEET NUMBER                                   |  |      |             |                                  |
| FIRE-1                                         |  |      |             |                                  |