

City of Albuquerque Stormwater Construction Site Inspection Report

General Information							
SC File No. M09E					Solare Collegiate Charter School Phase 3		
NPDES Id. No.	NMR10		Location: 8801 Gibson Blvd SW				
12/5/2024		Owner Callagiana Facus dahian			Contractor		
Operator		Solare Collegiate Foundation Rachel Sewards			Insight		
Contact name & title		rsewards@solarecollegiate.org					
e-mail Contact Phone #		505-917-6442®					
COA Inspector		James Hughes			Time	9:20am	
Construction Phase:					grading	· ·	
Type of Inspection:		Regular	Storm Event	Post Storm Ev		311/Complaint Follow Up	
Weath	er at time of i	inspection?		Temperature: ~ 50			
Estimated date of last storm 0.25" or greater							
Item	Deficiency/ Corrective Action						
Number	Deficiency/ Corrective Action						
1	Posting - CG	ng - CGP coverage was not posted so it is visible from the public road nearest to the active part of the					
	construction site, using a font large enough to be readily viewed from a public right-of-way in violation of CGP						
	1.5. Required Mitigation: You must post a sign or other notice of your permit coverage at a safe, publicly						
		essible location in close proximity to the construction site. The notice must be located so it is visible from					
	the public ro	lic road that is nearest to the active part of the construction site, and it must use a font large enough to					
	be readily via	y viewed from a public right-of-way per CGP 1.5.					
2	SW/DDD - Th	o SWDDD wasi	a't available on	-site in violatio	n of CGD 7.2	Poquired Mitigation: The SW/DDD	
	SWPPP - The SWPPP wasn't available on-site in violation of CGP 7.3. Required Mitigation: The SWPPP,						
	including the SWPPP Map, Self-Inspection Reports, and Corrective Action Reports, must be kept up-to-date per						
	CGP 7.1 and available on-site per CGP 4.7.3, 5.4.3 and 7.3. If an on-site location is unavailable to keep the						
	SWPPP when no personnel are present, notice of the plan's location must be posted near the main entrance of						
	your construction site CGP 7.3.						
2.1	Discharge off site?	(Y/N)	no	I			
		,					
4	Self Inspec	tion Reports	requested	Latest repo	ort Date:	none	
Notes:							

City of Albuquerque Stormwater Inspector Signature and date:

Contact information: James Hughes

jhughes@cabq.gov

12/11/24

James D. Hughes