

CITY OF ALBUQUERQUE



March 13, 2013

George Rodriguez,
Levi Valdez George Rodriguez Development Consulting
12800 San Juan NE
Albuquerque, NM 87102

**Re: Santuario de San Martin De Porres, Grading and Drainage Plan
Engineer's Stamp Date 3/16/2013 (M10/D002)**

Dear Mr. Rodriguez,

Based upon the information provided in your submittal received 3-12-13, the above referenced plan is approved for Foundation Permit only.

PO Box 1293

Please address the following comments prior to building permit approval:

Albuquerque

- Provide more spot elevations to assure that the runoff drains to the existing retention pond. Include the runoff and volume calculations for the basin that drains to the existing retention pond.
- Provide pond volume calculations to assure that the existing retention pond is designed for the 100-year/10-day volume.

NM 87103

If you have any questions, you can contact me at 924-3695.

www.cabq.gov

Sincerely,

Shahab Biazar, P.E.
Senior Engineer, Planning Dept.
Development and Building Services

C: email