

## Biazar, Shahab

---

**From:** Biazar, Shahab  
**Sent:** Wednesday, October 15, 2014 1:23 PM  
**To:** 'scott mcgee'  
**Cc:** Ortiz, Monica  
**Subject:** Erosion Sediment Control Plan For San Martin De Porres (M10E002)

Based upon the information provided in your submittal received 11-2-14, the Erosion Sediment Control (ESC) Plan for San Martin De Porres (M10E002) is not acceptable for building permit based on the following comments:

- Clearly show the Silt Fence locations.
- Include the location of the NPDES Posting Board (visible from Public right-of-way)
- Show the Staging Area.
- Include a note that "Project is required to maintain a regiment of street sweeping and clean up measures in the event of track out to minimize and prevent off site conveyances during construction."
- Provide stabilized construction entrance location and detail (depth should be 50' minimum)
- Provide details for all BMPs used on this site.
- Grading Plan must be approved prior to approval of the ESC plan.

Thanks and have a nice day.

***Shahab Biazar, P.E.***

*Acting City Engineer*  
Planning Department  
Development Review Services Division  
600 2nd St. NW, Suite 400  
Albuquerque, NM 87102  
t 505-924-3422  
f 505-924-3440