HYDROLOGY M14/D13 3 PLANS

M14/D13

3 Plans

Pre-Design Investigation
(Additions)

DATE 6-9-87

ADDRESS 2400 BROADWAY ZONE ATLAS # M14 /D13

LEGAL DESCRIPTION

OWNER

ARCHITECT/ENGINEER

LOT SIZE

ZONING

PROPOSED DEVELOPMENT STORAGE BLDG. FOR BERN. COUNTY PARKS & REC.

RECEIVED
JUN 09 1987
HYDROLOGY SECTION

	YES	NO	NA	COMMENTS
FLOOD HAZARD AREA		C		
PART OF AN APPROVED REPORT		/		
CONSTRUCTION PLANS ON MICRO-FILM		/		
FIELD INSPECTION	/			

COMMENTS:

AREA WHERE STORAGE BLDG TO BE CONSTRUCTED IS IN A LOW SPOT, BUT SITE WILL TEND TO DRAIN NORTH AND WEST OUT THRU ENTRY WAY

DRAINAGE REQUIREMENTS:

DRAINAGE INFORMATION SHEET

PROJECT TITLE: _____ ZONE ATLAS/DRNG. FILE #: M14

LEGAL DESCRIPTION: _____

CITY ADDRESS: _____

ENGINEERING FIRM: _____ CONTACT: _____

ADDRESS: _____ PHONE: _____

OWNER: _____ CONTACT: _____

ADDRESS: _____ PHONE: _____

ARCHITECT: _____ CONTACT: _____

ADDRESS: _____ PHONE: _____

SURVEYOR: _____ CONTACT: _____

ADDRESS: _____ PHONE: _____

✓ CONTRACTOR: AGRI BUILDING CO. CONTACT: LORI K. CHAVEZ

ADDRESS: 4330 BROADWAY SE. PHONE: 877-4155

RECEIVED
JUN 09 1987
HYDROLOGY SECTION

PRE-DESIGN MEETING:

___ YES

___ NO

___ COPY OF CONFERENCE RECAP SHEET PROVIDED

DRB NO. _____

EPC NO. _____

PROJ. NO. _____

TYPE OF SUBMITTAL:

___ DRAINAGE REPORT

___ DRAINAGE PLAN

___ CONCEPTUAL GRADING & DRAINAGE PLAN

___ GRADING PLAN

___ EROSION CONTROL PLAN

___ ENGINEER'S CERTIFICATION

X field inspection

CHECK TYPE OF APPROVAL SOUGHT:

___ SKETCH PLAT APPROVAL

___ PRELIMINARY PLAT APPROVAL

___ SITE DEVELOPMENT PLAN APPROVAL

___ FINAL PLAT APPROVAL

X BUILDING PERMIT APPROVAL

___ FOUNDATION PERMIT APPROVAL

___ CERTIFICATE OF OCCUPANCY APPROVAL

___ ROUGH GRADING PERMIT APPROVAL

___ GRADING/PAVING PERMIT APPROVAL

___ OTHER _____ (SPECIFY)

DATE SUBMITTED: _____

BY: _____

RECEIVED
JUN 09 1987
HYDROLOGY SECTION



FILE COPY

City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

Ken Schultz
Mayor

UTILITY DEVELOPMENT DIVISION
HYDROLOGY SECTION
(505) 768-2650

March 19, 1987

Carl Lovato
Bernalillo County Public Works Department
2400 Broadway, SE
Albuquerque, New Mexico 87102

RE: DRAINAGE PLAN FOR AN ADDITION TO THE BERNALILLO COUNTY ROAD DEPARTMENT ADMINISTRATION BUILDING (M-14/D13 RECEIVED MARCH 12, 1987

Dear Mr. Lovato:

Based on the information provided on your submittal of March 12, 1987, the above referenced plan is approved for Building Permit.

Please attach a copy of this plan to the construction sets prior to sign-off by Hydrology.

If I can be of further assistance, please feel free to call me at 768-2650.

Cordially,

Bernie J. Montoya

Bernie J. Montoya, C.E.
Engineering Assistant

BJM/bsj

DRAINAGE INFORMATION SHEET

PROJECT TITLE: 2400 BROADWAY S.E. - BERN CO. PUBLIC WKS DEPT. ZONE ATLAS/DRNG. FILE #: M14/D13

LEGAL DESCRIPTION:

CITY ADDRESS: 2400 BROADWAY SE

ENGINEERING FIRM: BERN. CO. PUBLIC WKS CONTACT: CARL LOVATO

ADDRESS: 2400 BROADWAY SE PHONE: 843-6120

OWNER: BERN. COUNTY CONTACT: JOHN RAMSEY

ADDRESS: 2400 BROADWAY SE PHONE: 843-6120

ARCHITECT: ERNEST VLIBARRI & ASSOC. CONTACT: ERNEST VLIBARRI

ADDRESS: PHONE: 242-1552

SURVEYOR: ALB. SURVEY COMPANY CONTACT: FRED SANCHEZ

ADDRESS: 2119 Menaul NE. PHONE: 884-2036

CONTRACTOR: — CONTACT: —

ADDRESS: PHONE:

RECEIVED MAR 12 1987 HYDROLOGY SECTION

PRE-DESIGN MEETING:

___ YES

✓ NO

___ COPY OF CONFERENCE RECAP SHEET PROVIDED

DRB NO. ___

EPC NO. ___

PROJ. NO. ___

TYPE OF SUBMITTAL:

___ DRAINAGE REPORT

✓ DRAINAGE PLAN

___ CONCEPTUAL GRADING & DRAINAGE PLAN

___ GRADING PLAN

___ EROSION CONTROL PLAN

___ ENGINEER'S CERTIFICATION

CHECK TYPE OF APPROVAL SOUGHT:

___ SKETCH PLAT APPROVAL

___ PRELIMINARY PLAT APPROVAL

___ SITE DEVELOPMENT PLAN APPROVAL

___ FINAL PLAT APPROVAL

✓ BUILDING PERMIT APPROVAL

___ FOUNDATION PERMIT APPROVAL

___ CERTIFICATE OF OCCUPANCY APPROVAL

___ ROUGH GRADING PERMIT APPROVAL

___ GRADING/PAVING PERMIT APPROVAL

✓ OTHER SITE INSPECTION by Rick Duran (SPECIFY)

DATE SUBMITTED: ___

BY: ___

Pre-Design Investigation
(Additions)

DATE 3-12-87

ADDRESS 7400 BROADWAY ZONE ATLAS # M14

LEGAL DESCRIPTION TR A & B MCKINNEY ARDAGA AREA

OWNER BERNALILLO COUNTY PUBLIC WORKS DEPT.

ARCHITECT/ENGINEER

LOT SIZE

ZONING

PROPOSED DEVELOPMENT 1300# ADDN.

RECEIVED
MAR 12 1987
HYDROLOGY SECTION

	YES	NO	NA	COMMENTS
FLOOD HAZARD AREA		✓		
PART OF AN APPROVED REPORT		✓		
CONSTRUCTION PLANS ON MICRO-FILM		✓		
FIELD INSPECTION	✓			3-12-87

COMMENTS:

DRAINAGE RUNS TOWARDS WEST WHERE IT ENTERS A DEPRESSED PONDING AREA ALONG BROADWAY. SOME RUN-OFF WILL ENTER 2 INLETS - ONE INSIDE SIDE & ONE OUTSIDE SITE. ADDN. WILL BE OVER EXIST. ASPHALT

DRAINAGE REQUIREMENTS: