



Merrick & Company
5970 Greenwood Plaza Blvd
Greenwood Village, CO 80111
Tel: 303-751-0741
Fax: 303-751-2581
www.merrick.com

December 24, 2015

Ms. Stanice 'Totten' Elliott
Hydrology Section
City of Albuquerque

RE: Chick-fil-A at 1600 Gibson Blvd – Hydrology Final items for Permanent CO

Ms. Elliott,

Please find attached to this letter several photos depicting the completed items per the temporary certificate of occupancy. The deficient items were listed as:

1. The pond on the south side must be completed.
2. The drain the dumpster must be cut at grade and a drain placed over it.
3. The 12 x 12 area drain on the NW corner must be cut and grate placed over it.

Per my site inspection on December 22, 2015 all of the items listed above have been completed. Please accept the photos included in Attachment A as proof of completion.

Should you need additional photos or documentation, please do not hesitate to contact me directly at 303-353-3926.

Thank you for all your help to get this project pushed over the finish line.

Sincerely,

Troy Kelts, PE

On behalf of Merrick & Company

Attachment A

1. Pond on the south side of property has been completed. Landscaping installed. Side slopes and bottom of pond seeded per the landscaping plans. Rip rap has been installed around pond inlet.



2. The drain in the dumpster has been cut and a drain cover has been installed.



3. The 12 x 12 area drain has been completed.

