



City of Albuquerque Stormwater Construction Site Inspection Report

General Information

ESC File No.	M15E021C	Project Name:	Dutch Bros. NM0303
NPDES Id. No.	NMR1005GM	Location:	2131 Gibson Blvd SE
10/23/2023	Owner	Contractor	
Operator	Dutch Bros, LLC		
Contact name & title	Daniel Batty		
e-mail	daniel.batty@dutchbros.com		
Contact Phone #	541-955-4700		
COA Inspector	Chancellor English	Start/End Time:	1230pm
Construction Phase:	Excavation, utilities		
Type of Inspection:	Regular	Storm Event	Post Storm Event >0.25"
		311/Complaint	Follow Up
Weather at time of inspection?	Clear	Temperature: ~	70
Estimated date of last storm 0.25" or greater	9/13/2023		

Item Number	Deficiency/ Corrective Action		
1	The SWPPP is missing the Certification page (CGP Part 7.2.10), the NOI (7.2.11), and training certificates for inspector. (7.2.2) Required mitigation: Provide the certification page, the NOI and training certificates for your inspectors.		
2.1	Discharge off site? (Y/N)	no	
4	Self Inspection Reports	Yes	Latest report Date: 10/16/2023

Notes:	
Previous violations include Posting, SWPPP, BMPs	

City of Albuquerque Stormwater Inspector Signature and date: 10/23/2023
Contact information: Chancellor English (505) 924-3325
cenglish@cabq.gov

Chancellor English