

City of Albuquerque Stormwater Construction Site Inspection Report

General Information								
ESC File No.	M15EC	023B Project Name:			Avid Hotel			
NPDES Id. No.	NMR1006.	JO & 6IR Location:			1441 Woodward Rd. SE			
	3/2025	Owner			Contractor			
Operator		1441 Sunport, LLC			HEI Construction, LLC			
Contact name & title		R-Nicholas Eveleigh			Yogash Kumar			
e-mail		heiconstruction@yahoo.com & rne@hr			yogash@hmsgallup.com 505-879-7613			
Contact Phone #								
COA Inspector		Chancellor English			Start/End Time	Time: 11:30am		
	tion Phase:				Verticals			
Type of In								
	er at time of in	·			Temperature: ~ 85			
Estimated	date of last s	torm 0.25" or greater			5/4/2025			
Item								
	Deficiency/ Corrective Action							
Number								
1	The self-inspection reports were not up-to-date in violation of CGP Part 4.7.3. Required mitigation: You must							
	keep a copy of all inspection reports at the site or at an easily accessible location so that they can be made							
	immediately available at the time of an on-site inspection per CGP Part 4.7.3.							
2.1	Discharge off site?	(Y/N)	No					
4	Self Inspect	ion Report	s Yes	Latest re	port Date:		4/17/2025	
			•					
Notes:	otes:							
The previous violations (Waste, Washout, BMPs) have been mitigated.								
The new concrete entrance onto Flightway Ave. (north side of site) is a discharge point and needs to be								
protected from any sediment discharges.								
,								

City of Albuquerque Stormwater Inspector Signature and date: 5/29/2025

Contact information: Chancellor English 505-924-3325

cenglish@cabq.gov

Chancellor English