


CITY OF ALBUQUERQUE



March 21, 2019

Yogash Kumar; Sunport Park Hospitality; rne.hms@gmail.com
Nicholas Eveleigh; rne.@hmsgallup.com

Site: Comfort Suites, 1401 Woodward Rd SE

**Re: Drainage Ordinance (14-5-2-1) Violations for Erosion and Sediment Control
and Construction Site Waste(s)**

Dear Mr. Kumar,

The following violations were observed at today's inspection.

1. A section of the silt fence was not buried along the western edge.
2. The site is not posted.
3. Waste container was not covered/no ability to cover waste container.
4. SWPPP self-inspection reports have not been provided.

Photos are shown below:



Silt fence not buried along western edge.

PO Box 1293

Albuquerque

NM 87103

www.cabq.gov

CITY OF ALBUQUERQUE



Waste container not covered/no ability to cover.

PO Box 1293

Albuquerque

NM 87103

www.cabq.gov

**Required Mitigation:**

1. Bury the silt fence along the western edge.
2. Post the site per paragraph 1.5 of the NPDES Construction General Permit.
3. Provide the ability to cover the waste container and cover the waste container when not in use.
4. Provide a SWPPP self-inspection report that shows the inspection has been completed within the past two weeks. SWPPP self-inspection reports are required to be completed once every 14 days and within 24 hours of a rainfall event of 0.25 inches or greater until the site is deemed stabilized by the City.

Per the previous Violation letter, the City is assessing a fine of \$500. This fine is for one day.

Additional days may be added if the violations are not mitigated upon a follow-up inspection in ten days. In addition, your non-compliance may be reported to the New Mexico Environment Department, Surface Water Quality Bureau to aid in the determination if this issue is to be forwarded to the EPA.

If you would like to schedule a follow-up inspection at a day and time of your convenience, prior to 10 days from the date of this letter please let me know.

If you have any questions, you can contact me at 924-3420.

PO Box 1293

Albuquerque

NM 87103

www.cabq.gov

Sincerely,

Curtis Cherne, P.E.

Principal Engineer, Stormwater Quality
Planning Dept.