

CITY OF ALBUQUERQUE



July 18, 2014

Philip W. Clark, P.E.
Clark Consulting Engineers
19 Ryan Rd.
Edgewood, New Mexico 87015

**RE: AJDJ Hospitality, Erosion and Sediment Control Plan
Engineers Stamp Date 5-28-14 (M15E023G)**

Dear Mr. Clark,

Based upon the information provided in your submittal received 5-29-14, the above referenced Erosion and Sediment Control Plan is approved for Grading Permit based on the following condition:

PO Box 1293

_Slope ties extend beyond the property. This appears to be a drafting error. No grading should occur on the adjacent property unless authorization by the owner in writing.

Albuquerque

This project requires a National Pollutant Discharge Elimination System (NPDES) permit for storm water discharge for disturbing one acre or more and a Topsoil Disturbance Permit for disturbing $\frac{3}{4}$ of an acre or more.

New Mexico 87103

If you have any questions, you can contact me at 924-3999.

www.cabq.gov

Sincerely,

Shahab Biazar, P.E.
Acting City Engineer, Planning Dept.
Development Review Services

C: e-mail