

CITY OF ALBUQUERQUE



June 12, 2013

Jeffrey T. Wooten, P.E.
Tierra West, LLC
5571 Midway Park Pl. NE
Albuquerque, NM 87109

**Re: Capstone Student Housing Erosion and Sediment Control Plan
Engineer's Stamp dated 05-17-2013 (M-15/D026)**

Dear Mr. Wooten,

Based upon the information provided in your submittal received 05-17-13, the above referenced plan cannot be approved for Erosion and Sediment Control Plan until the following comments are addressed:

1. Provide finished contours on the ESC plan.
2. The ESC plan must be oriented in the same manner as the submitted grading and drainage plan.
3. Clarify the extents of the grading operations to take place for the mitigation area; the proposed layout for the silt fence encompasses the entire lot, however, the associated grading plan only calls for grading permit in the mitigation area.

PO Box 1293

If you have any questions, you may contact me by telephone at 505-924-3695.

Albuquerque

New Mexico 87103

www.cabq.gov

Sincerely,

Shahab Biazar, P.E.
Senior Engineer, Planning Department
Development and Building Services