

CITY OF ALBUQUERQUE



September 20, 2013

David Soule, P.E.
Rio Grande Engineering
P.O. Box 93924
Albuquerque, NM 87199

Re: **Hampton Inn At The Sunport Grading and Drainage Plan**
Engineer's Stamp dated 9-05-13 (M15/D043)

Dear Mr. Soule,

Based upon the information provided in your submittal received 9-05-13, the above referenced Grading Plan can not be approved for building permit based on the following comments:

- Please make sure all the proposed spot elevations are legible.
- Easement is required from the property owner to the east for the placement of the retaining wall.
- As previously asked, please show the location of the cobble swale on the grading plan or remove the detail if a swale is not needed.

If you have any questions, you can contact me at 924-3695.

Sincerely,

Shahab Biazar, P.E.
Senior Engineer, Planning Dept.
Development and Review Services

PO Box 1293

Albuquerque

New Mexico 87103

www.cabq.gov

C: E-mail