

# CITY OF ALBUQUERQUE



August 26, 2013

Åsa Nilsson-Weber  
Isaacson & Arfman, P.A.  
128 Monroe St. NE  
Albuquerque, NM 87108

**Re: Four Hills Park Grading and Drainage Plan**  
**Engineer's Stamp date 08-14-13 (M22/D008)**

Based upon the information provided in your submittal received 8-14-13, the grading and Drainage Plan is approved for Grading Permit, Paving Permit, and Work Order.

This project requires a National Pollutant Discharge Elimination System (NPDES) permit for storm water discharge for disturbing one acre or more and a Topsoil Disturbance Permit for disturbing  $\frac{3}{4}$  of an acre or more. Please attach a copy of this approved plan to the construction sets prior to sign-off by Hydrology. Engineer Certification will be required at the end of the project

PO Box 1293

Albuquerque

If you have any questions, you can contact me at 924-3695.

New Mexico 87103

Sincerely,

Shahab Biazar, P.E.  
Senior Engineer, Planning Dept.  
Development Review Services

[www.cabq.gov](http://www.cabq.gov)

C: e-mail