

From: [Hughes, James D.](#)
To: Eloven@lgihomes.com
Subject: N09E014 - NMR1000BE - Desert Sands - Violation at offsite pond
Date: Tuesday, March 09, 2021 10:49:00 AM
Attachments: [03.08.21R_Inspection-signed.pdf](#)
[TimePhoto_20210308_162322.jpg](#)
[TimePhoto_20210308_162409.jpg](#)
[TimePhoto_20210308_162412.jpg](#)
[SECT 632 \(1-1-19\) SP.PDF](#)
[CGP2017 Final Stabelization.pdf](#)

Eddie,

Please find attached yesterday's inspection report, photos, excerpts from CGP 2.2.14 with the Final Stabilization Criteria highlighted, and NMDOT SECT 632. Self-inspections are required every 2 weeks until you satisfy the Final Stabilization Criteria. Please e-mail the most recent self-inspection.

I recommend quickly satisfying the Final Stabilization Criteria in the CGP by applying the NMDOT Class A seeding procedures and substituting rock mulch instead of straw, then remove any remaining BMPs and file the NOT.



DOUG HUGHES, P.E., CFM, CPESC
principal engineer construction SWQ
o 505.924.3420
e jhughes@cabq.gov
cabq.gov/planning