

City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

December 8, 1993

Chris Weiss, P.E. C.L. Weiss Engineering P.O.Box 97 Sandia Park, N.M. 87047

RE: ENGINEER'S CERTIFICATION FOR AIRBORNE (N-15/D1A5);
RECEIVED NOVEMBER 29, 1993 FOR CERTIFICATE OF OCCUPANCY APPROVAL
STAMPED & DATED 11-22-93

Dear Mr. Weiss:

Based on the information included in the submittal referenced above, City Hydrology releases a Permanent Certificate of Occupancy for this project.

If I can be of further assistance, You may contact me at 768-2727.

Sincerely,

John P. Curtin, P.E. Civil Engineer/Hydrology

xc: Alan Martinez

WPHYD/7573/jpc



City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

March 30, 1995

James Topmiller Bohannan-Huston, Inc. 7500 Jefferson NE Albuquerque, NM 87109

RE: AIRPORT TECHNICAL CENTER EAST (N15-D1) BORROW SITE FOR SUNPORT PROJECT.

The following are City Hydrology's comments on your grading permit request. Given that this grading permit request is for a borrow pit for the Sunport project, which is not typical of development grading permit requests, I solicited comments from Loren Meinz for EPA requirements.

- The contractor must file a "Notice of Intent" (NOI) for construction activity with E.P.A. and must have an appropriate pollution prevention plan. See typical details in the Sunport Construction Plans for level of detail expected. The pollution prevention plan must address on-site disiltation ponds and must be maintained during construction and after construction until the vegetation has established. (NOI application attached).
- Provide existing and proposed ortho-topo map with horizontal and vertical control.
- Provide construction schedule for the borrow pit operation and the anticipated completion of final grading.
- Include with your resubmittal the calculations for the identified flow rates.
- Follow Section 1012 of the City Standard Specification and/or specific requirements addressed in the Topsoil Disturbance Permit.
- Coordinate with and address concerns of all City, County, State and Federal Agencies involved with the Sunport Project and provide confirmation that such has been done.

James Topmiller Page 2

> All requirements, etc. on Sunport now apply to this project.

If you have any questions, contact me at 768-2668.

Sincerely,

Fred J. Aguirre P.E.

City Hydrologist

C: Dan Hogan
Dave Harmon
Russell Givler
Loren Meinz
Larry Caudill

File



City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

May 3, 1995

James Topmiller Bohannan-Huston, Inc. 7500 Jefferson NE Albuquerque, NM 87109

RE: REVISED GRADING PLAN FOR AIRPORT TECHNICAL CENTER EAST

(N15-D1) ENGINEER'S STAMP DATED 4/18/95.

Dear Mr. Topmiller:

Based on the information provided on your April 21, 1995 resubmittal, the above referenced site is approved for Grading.

Please be advised that it will be the contractor's responsibility to continue maintenance on the proposed desilting pond and rundown at the southwest corner of the property.

If I can be of further assistance, please feel free to contact me at 768-2667.


Sincerely,

Bernie J. Montoya, CE Engineering Associate

BJM/dl

c: Andrew Garcia Larry Caudill

<File>



Public Works Department May 30, 1997

Martin J. Chávez, Mayor

Robert E. Gurulé, Director

James Topmiller Bohannan Huston, Inc. 7500 Jefferson NE Albuquerque, New Mexico 87109

RE: Drainage Plan for Airport Technical Center East (N15-D1) Received May 6, 1997

Dear Mr. Topmiller:

Based on the information provided on your May 5, 1997 submittal, the above referenced site is approved for grading.

Please be advise that it will be the owner's responsibility to continue maintenance on the proposed distilling pond, erosion control measures, and rundown.

If you have any questions please call me at 924-3984.

Sincerely,

Carlos A. Montoya

Project Manager

c: Andrew Garcia File

