

City of Albuquerque Stormwater Construction Site Inspection Report

General Information

ESC File No.	P09E002D CV	Project Name:	Ceja Vista Unit 1		
NPDES Id. No.	NMR100ZBE	Location:	9800 Dsennis Chavez SW		
1/22/2021	Dennis Chavez		Contractor		
Operator	Ceja Vista LLC		Franklins		
Contact name & title	Bill Allen manager		Gus Harbaugh		
e-mail	ballen@westpacnm.com		Gus.Harbaugh@feinm.com		
Contact Phone #	505-440-7262		w796-5457 m975-2864		
COA Inspector	Doug Hughes		Start/End Time:	3pm	
Construction Phase:	infrastructure complete				
Type of Inspection:	Regular	Storm Event	Post Storm Event >0.25"	311/Complaint	Follow Up
Weather at time of inspection?	Cloudy		Temperature: ~	45	
Estimated date of last storm 0.25" or greater	12/11/2020				
Item Number	Deficiency/ Corrective Action				
1	Silt fence down and full of sediment reset all and add more along Dennis Chaves				
2	Remove sediment from street and sidewalk.				
3	Inlet protection needs maintenance				
4	Stabilize all disturbed areas				
5	Provide self inspection reports				
2.1	Discharge off site? (Y/N)	no			
4	Self Inspection Reports	Requested	Latest report Date:	2/12/2020	

Notes:	

City of Albuquerque Stormwater Inspector Signature and date:
Contact information: Doug Hughes (505) 924-3420
jhughes@cabq.gov