

CITY OF ALBUQUERQUE



October 17, 2017

Diane Hoelzer, P.E.
Mark Goodwin and Associates
P.O. Box 90606
Albuquerque, NM 87199

**Re: Valle de Atrisco
Erosion and Sediment Control Plan
Engineer's Stamp Date 9-28-17 (P09E002D)**

Dear Ms. Hoelzer,

Based upon the information provided in your submittal received 9-28-17, the above referenced plan is not approved to be included in the SWPPP or to apply for an ESC permit for grading and Building Permit until the following comments are addressed:

1. The plan does not show the project limits. The grading plan shows a ditch and a pond south and east of the project in Bernalillo County.

2. The disturbance in Bernalillo County is to be approved by Bernalillo County.

Provide the City with an approval letter from Bernalillo County.

3. Provide grades. Additional comments may arise once grades are provided.

4. From aerial imagery, it appears the offsite flows will miss the proposed pond. How does the drainage enter the proposed pond east of the project?

5. Provide inlet protection for proposed inlets.

6. BMPs have not been proposed for the trail on Dennis Chavez and for construction of 98th St. Will there be a separate plan for Work Order approval?

If you have any questions, you can contact me at 924-3420.

Sincerely,

Curtis Cherne, P.E.
Principal Engineer, Stormwater Quality
Planning Dept.