

# Ceja Vista Senior Apartments DBG Properties, LLC. General Permit SWPPP Inspection



Last Rain Event

Last Precipitation

48h Forecast

Friday, December 11, 2020, Wednesday, January 27, 2021,

0.05"

22% Chance of Rain

Inspection Date and Time

Completed by

Frequency

NMR10032D

Permit #

Jan 28, 2021, 11:00:25 AM

Jeff Hart Bi-weekly -

Inspection Form Instructions - Review each question for this inspection carefully, then answer YES, NO, or N/A (not applicable). If any of the items below are out of compliance, press the "Add Action Item" button above to add a corrective action.

### General Information

Inspector's Qualifications - Trained and work experience - see inspector qualification page in section 2 of the SWPPP.

## Type of Inspection:

#### Regular

During storm

event

Post storm event

### Weather Information

Last Storm Event Information - For information on the last storm event, see the weather event information at the end of this inspection.

Weather at time of this inspection?

Clear

#### Cloudy

Rain

Sleet

Snowing

**High Winds** 

**Partly** 

Cloudy

Have any discharges occurred since the last inspection?

Yes

No

If yes, what did the water look like at the time of the discharge? Are there any discharges at the time of this inspection? Yes No If yes, what did the water look like at the time of the discharge? Is a rain gauge installed on site? Yes No If yes, where is it located? Nearby gauge, NOAA, COCORHAS and Weather Underground monitored as secondary resources. Has the Rain Event Page been filled out? Yes No Are there SDS sheets on site? Yes No If yes, where are they located? Inspectors log updated. SDS sheets on site in DBG construction trailer. If construction ceases on the site for more than 14 days, the site must be stabilized until construction resumes. **Date Construction Stopped Date Construction Resumed** Measures Taken to Stabilize the Site: Construction Phasing Verify what stage of construction the project is in, and record dates when activities started and

were completed.

#### Installed BMPs

Not

Started

Started

Completed

Started: 08/20

Completed: 08/20

Site Clearing and Grading

	Started		
ı	Started Started		
ı	Started  Completed		
	<del>Completed</del>		
Star	ted: 08/20		
Con	npleted: 01/21		
Insta	alling Utilities		
	Not Control of the Co		
ı	Started Started		
	Completed		
Star	ted:		
Con	npleted:		
Buil	ding Structure		
Star	ted:		
0			
Con	npleted:		
Pav	ing and Walks		
	Not		
ı	Started		
	Started Company of the Indian Company of the		
	Completed		
Star	ted:		
Car	anleted:		
CUII	npleted:		
Fina	al Grading/Stabilize Site		
Started:			
Completed:			
Other			
Started:			
Si	te-specific BMPs		

List of BMPs Installed:
Silt Fence, Earth Berm, Retaining Wall (IN PROGRESS/ EAST SIDE AT VALLE DE ATRISCO APTS. South to North),
Staging Area, Stabilized Access Point- Street in place 98th to fractured rock pad access.

The corrective actions initiated and date completed are in the Corrective Action Log

Are all of the above controls installed?  Yes  Ne			
Do any of the above controls need maintenance?  Yes  No			
If any of the controls have not been installed or require maintenance, please list the control and explain. Silt fence install continues along Dennis Chavez, east to west, parallel to ROW and newly installed swale. Culvert protection to accompany BMP's at the intersection of 98th and Dennis Chavez. See ECP for details. Install fractured rock access pad, as designated by the ECP, SW corner access to Valle De Atrisco apartments.			
Are the BMPs shown on the map?  Yes  No			
Were there any changes to the SWPPP?  Yes  No			
Has the SWPPP been updated?  Yes  No			
Were the changes to the SWPPP implemented within 7 days?  Yes  No			
List any new BMPs needed:  NO changes to the SWPPP document at this time. Install fractured rock access pad, as designated by the ECP, SW corner access to Valle De Atrisco apartments. Replace/ repair weathered fence "Tract RR-3-B-1", east of VDA apartments.			
Notes: Earth berm in place east of DBG offices, temporary stabilization efforts will be required after 14 days. No sign of soil degradation at the time of inspection, hardened berm.			
Oversight Issues			
A list of corrective actions will be supplied with this inspection.			
Are all slopes and disturbed areas not actively being worked properly stabilized?			
Implemented?  Yes  No N/A			
Maintenance Required?			

Yes

	No N/A				
	Are natural resources (e.g., streams, Arroyos, mature trees, etc.) protected with barriers or milar BMPs?				
Impl	mplemented?  Yes  No  N/A				
Mair 	No N/A				
	Are perimeter controls and sediment barriers adequately installed (keyed into substrate) and aintained?				
Impl	emented? Yes No N/A				
Mair 	Nes No N/A				
4.	Are discharge points and receiving waters free of any sediment deposits?				
Impl	emented? Yes No N/A				
Mair 	ntenance Required?  Yes  No  N/A				
5.	5. Are storm drain inlets properly protected?				
Impl	emented?  Yes  No  N/A				
Mair	ntenance Required?  Yes				

ı	No N/A		
6.	6. Is the construction exit preventing sediment from being tracked into the street?		
Imp 	lemented? Yes No N/A		
Maii	ntenance Required?  Yes  No  N/A		
7.	Is trash/litter from work areas collected and placed in dumpsters?		
Imp 	lemented?  Yes  No  N/A		
Mai	No N/A		
	Are washout facilities (e.g., paint, stucco, concrete) available, clearly marked, and aintained?		
Imp	lemented?  Yes  No  N/A		
Mai	No  N/A		
	Are vehicle and equipment fueling, cleaning, and maintenance areas free of spills, leaks, or by other deleterious material?		
Imp 	lemented?  Yes  No No N/A		
Mai	ntenance Required		

_	105		
	No		
	N/A		
10	). Are materials that are potential storm water contaminants stored inside or under cover?		
aml	lemented?		
	<del>Yes</del>		
	No.		
- 1	N/A		
Mai	ntenance Required?		
	<del>Yes</del>		
	No		
•	N/A		
11	I. Are non-storm water discharges (e.g., wash water, dewatering) properly controlled?		
	3 ( 3 / 3 / 3 / 1 )		
Imp	lemented?		
Ĺ	Yes		
•	No No		
	N/A		
Mai	ntenance Required?		
	<del>Yes</del>		
	No		
	N/A		
12	2. Has the Site map been updated to reflect current conditions?		
Imp	lemented?		
	Yes		
	<del>No</del>		
	<del>N/A</del>		
Mai	ntenance Required?		
	<del>Yes</del>		
	No		
	N/A		
13	3. Is the NOI posted?		
Imp	lemented?		
	Yes		
	No.		
	<del>N/A</del>		
Maintananca Paguirad?			
iviai	Maintenance Required?  Yes		
1	ार्च 		

N/A		
	14. Were previous corrections made within 7 days of last inspection or before the next storm event?	
Ir	mplemented?	
	Yes	
	<del>No</del>	
	N/A	
٨	Maintenance Required?	
	Vac	

Walk through facility and look for signs of pollution including paint, solvents, chemicals, solid waste, oil, and fuel.

Are there any signs of hazardous materials being exposed to storm water runoff? <del>Yes</del>

No

No N/A

No

Have there been any reportable quantities releases of hazardous materials?

Yes

No

**Additional Notes** 

## Certification

### **Certification Statement:**

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gathered and evaluated the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

Electronic Signature			
X Jeff Hart	Date January 30, 2021 at 6:46:59 AM MST		
Title Senior Inspector			

#### Weather History Precipitation Recorded No Precipitation Missed or data unavailable January th th th th th th 0.01' th 0.02" 0.01" th st nd rd th 0.07" th 0.05" th th

All precipitation totals are obtained from the National Oceanic and Atmospheric Administration (NOAA). Precipitation readings are based on the latitude and longitude for each site as entered into complianceGO. Occasionally NOAA fails to return/record data. Days where this occurs are so indicated.

There Are No Action Items