

# CITY OF ALBUQUERQUE



March 4, 2014

David Soule, P.E.  
Rio Grande Engineering  
P.O. Box 93924  
Albuquerque, NM 87199

**Re: Lamonica Shops - 3510 Coors Blvd. SW  
Erosion Sediment Control (ESC) Plan  
Engineer's Stamp Date 1/28/2014 (P10E005)**

Dear Mr. Soule,

Based upon the information provided in your submittal received 1-29-14, the above referenced plan is acceptable for Grading Permit based on the following comments:

- What is the scale of the drawing?
- The entrance hatch should be 50' minimum.
- Show the sign posting location.
- The detail sheet is not legible.

PO Box 1293

Albuquerque

If you have any questions, you can contact me at 924-3695.

New Mexico 87103

Sincerely,

www.cabq.gov

Shahab Biazar, P.E.  
Principal Engineer Planning Dept.  
Development Review Services

C: e-mail