

CITY OF ALBUQUERQUE

Planning Department
Brennon Williams, Director



Mayor Timothy M. Keller

August 4, 2020

Nypro Healthcare Baja, Inc. – Sonya Woodhouse, sonya_woodhouse@jabil.com

Site: Jabil – 3801 University Blvd. SE - P15E003

Re: Drainage Ordinance (14-5-2-1) Violations for Erosion and Sediment Control

The following violations were observed at today's inspection.

1. Construction has continued beyond the project completion date on NPDES Permit, NMR1002UF, and the new R factor is above five, so NPDES Permit coverage is required per the last sentence in section C.1 of Appendix C of the Construction General Permit (attached).

Photos are shown below.



Required Mitigation:

1. Obtain NPDES Permit and submit to me and post notice on perimeter for safe public viewing or complete final stabilization.

If the violations are not mitigated within 14 days, the property owner is subject to a fine of \$500/day per the City's Drainage Control Ordinance and the non-compliance will be reported to the EPA.

If you have any questions, you can contact me at 924-3420, jhughes@cabq.gov .

Sincerely,

James D. Hughes

James D. Hughes, P.E.
Principal Engineer, Hydrology/Stormwater Quality
Planning Dept.