

CITY OF ALBUQUERQUE



December 24, 2018

Mike Balaskovits, P.E.
Bohannon Huston, Inc.
7500 Jefferson St NE Courtyard 1
Albuquerque, NM 87114

**Re: Mesa Del Sol Unit 3B
Erosion Sediment Control Plan
Engineer's Stamp Date 12-19-18 (R16E006)**

Dear Mr. Balaskovits,

Based upon the information provided in your submittal received 12-21-18, the above referenced plan is approved to be included in the SWPPP and to apply for an ESC Permit for grading and Building Permit and Work Order.

In the future:

1. Provide existing and proposed grades. The best way to accomplish this may be to superimpose the BMPs on the grading plan.
2. Show all areas of disturbance.

PO Box 1293

Happy Holidays!

Albuquerque

If you have any questions, you can contact me at 924-3420.

New Mexico 87103

Sincerely,

Curtis Cherne, P.E.
Principal Engineer, Stormwater Quality
Planning Dept.

www.cabq.gov

C: email