

**NOTE: 2016 Protocol - Maximum
of one SSWR per permit**

PROPRIETARY COMPANY MATERIAL



Date & Time : 04-22-2021 at 10:10 AM

**NATIONAL STORM WATER QUALITY PROGRAM
SITE INSPECTION REPORT (SIR)**

For use on most PulteGroup Sites as of 01/01/2016

Community Name: Pulte: Mesa Del Sol Unit 3 B, Albuquerque, NM NPDES: NMR1002K1
(Include Site Name, City, State, Zip Code and NPDES/Construction Storm Water Permit Number)

Master Site List ID: _____ Inspection performed by: Mario Alderete, Inspector, Green Globe Environmental
(Print Name, Company, and Title / Qualifications)

Stages of Construction: (check all that apply) ☐ Land Development ☐ Inactive ☒ Vertical Construction ☐ Post-Construction
☐ Land and Vertical
Type of Inspection: (check all that apply) ☒ Routine Inspection ☐ Storm-Event Related ☐ Final Site Inspection
☐ Other:

I. SWPPP - Respond to all Questions

<u>Item</u>		<u>Yes</u>	<u>No</u>	
A	Was the SWPPP accessible at the time of the inspection?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	If "No," then an Action Item is required. Describe all Action Items on the reverse side of this sheet. (Section IV)
B	Is the SSWR correctly identified in the SWPPP?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
C	Does the SWPPP reflect the current stage of development?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
D	Have all SIR action Items identified on the preceding reports been resolved?	<input type="checkbox"/>	<input type="checkbox"/>	
E	Is NSQP Signage posted and in compliance with NSQP requirements?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	

II. Estimated date of most recent Storm Event That triggered an Inspection: 11-07-2020
Provide rainfall information as required by the Applicable Permit: .25 Inches

(Base on the storm-event related Inspection Frequency required by the Applicable Permit)

III. Site BMP Inspection

<u>Item</u>	<u>SWPPP Items</u>	<u>Not Applicable</u>	<u>Acceptable</u>	<u>Action Item</u>	<u>Assigned To</u>
Erosion Control					
1	Protection of Disturbed Areas	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	_____
2	Slope Protection	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	_____
3	Vegetation / Revegetation	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	_____
4	Velocity Reduction Devices / Outlet Protection	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	_____
Sediment Control					
5	Check Dams (rock, gravel, other)	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	_____
6	Silt Fence	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	_____
7	Berms, Dikes, Straw Wattles	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	_____
8	Detention Basins/Sediment Traps	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	_____
9	Stockpiles Protected/Stabilized	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	_____
10	Storm Water Inlet Protection	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	_____
Housekeeping / Trade Compliance					
11	Waste and Trash Management	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	_____
12	Spill and Leak Prevention	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	_____
13	Sanitary Stations	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	_____
14	Concrete and Construction Washouts	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	_____
15	Material Use and Potential Contaminate Storage	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	_____
16	Equipment Storage and Maintenance	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	_____
17	Construction Exits and Entrances	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	_____
18	Dust Control	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	_____
19	Street Sweeping	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	_____

PROPRIETARY COMPANY MATERIAL

<u>Item</u>	<u>SWPPP Items (continued)</u>	<u>Not Applicable</u>	<u>Acceptable</u>	<u>Action Item</u>	<u>Assigned To</u>
20	Non-Storm Water Flow	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
21	Site's Weathering of Storm Events	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
22	Site Discharge Points	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
23	BMP Provider Performance	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	


IV. Action Items

V. Responsive Action Completion

<u>Item</u>	<u>Location and Responsive Action to be taken</u>	<u>Date Noted</u>	<u>Date of Completion</u>	<u>Initials</u>
11	Deficiency Name: Rejoining & scorsese Corrective Action: Contain blow trash	03-04-2021		
11	Deficiency Name: 6120 whyet Corrective Action: Drywall materials need to be cleaned up	03-18-2021		
14	Deficiency Name: 6123 whyet Corrective Action: Clean up concrete washout	02-25-2021		
19	Deficiency Name: Houser ave Corrective Action: Street needs to be cleaned up	04-01-2021		
23	Deficiency Name: 6120 wyeth Corrective Action: Cut curb back	03-18-2021		
23	Deficiency Name: 6113 whyet Corrective Action: Cut curb back	03-18-2021		
23	Deficiency Name: 6124 whyet Corrective Action: Cut curb back	03-18-2021		
23	Deficiency Name: 6128 whyet Corrective Action: Cut curb back	03-18-2021		
23	Deficiency Name: 2612 houser Corrective Action: Cut curb back	04-15-2021		

Attach additional sheet(s) of SIR addendum if necessary

SIR must be reviewed and signed below by SSWR - Not Delegable: I certify under penalty of law that Sections I-V of this document and all attachments were prepared by me or under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gathered and evaluated the information submitted. Based on my inquiry of the persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. In the event there are no Action Items in this report that have remained unresolved for a period in excess of that allowed by the Applicable Construction General Permit, I further certify under penalty of law that this Site is in compliance with the SWPPP and the Applicable Construction General Permit. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment for knowing violations. Certification applies to the area under the supervision of the SSWR signing this report.

Certified By: (SSWR - Must be a PulteGroup Employee)		Certified By: (Third Party Inspector if required by the Applicable Permit)	
		Mario Alderete	
Site Storm Water Representative - Print Name and Title		Inspector - Print Name	
			
Site Storm Water Representative Signature (Use Ink)	Date	Inspector Signature (Use Ink)	Date

VI. Justification for non-completion of Responsive Actions

Describe why any Responsive Actions were not corrected within the permit required time period (if applicable).

N/A

Attach additional sheet(s) if necessary