



# City of Albuquerque Stormwater Construction Site Inspection Report

## General Information

ESC File No.	R16E100	Project Name:	Bobby Foster Blvd. and University Blvd. Improvements Phase 1		
NPDES Id. No.	NMR1003I5/NMR1003OM	Location:	Bobby Foster Blvd. and University Blvd.		
11/5/2024	Owner	Contractor			
Operator	MDS Investments, LLC	Guzman Construction Solutions, LLC.			
Contact name & title	Eddie Gonzales	Eddie Gonzales			
e-mail	<a href="mailto:eddie@guzmancs.com">eddie@guzmancs.com</a>	<a href="mailto:eddie@guzmancs.com">eddie@guzmancs.com</a>			
Contact Phone #	505-452-0663	505-452-0664			
COA Inspector	Chancellor English	Start/End Time:	12:30-1:30pm		
Construction Phase:	Grading, infrastructure				
Type of Inspection:	<input checked="" type="checkbox"/> Regular	<input type="checkbox"/> Storm Event	<input type="checkbox"/> Past Storm Event >0.25"	<input type="checkbox"/> 311/Complaint	<input type="checkbox"/> Follow Up
Weather at time of inspection?	clear		Temperature: ~	60	
Estimated date of last storm 0.25" or greater	11/4/2024				
Item Number	Deficiency/ Corrective Action				
1	None observed.				
2.1	Discharge off site? (Y/N)	no			
4	Self Inspection Reports	Requested	Latest report Date:	10/30/2024	

## Notes:

Heavy equipment is being parked in the stockpile area adjacent to the Montage Units 5 and 6. If the developers are allowed to store the equipment on your property, your SWPPP map will need to be amended to reflect equipment storage along with the stockpiles.

City of Albuquerque Stormwater Inspector Signature and date: 11/14/2024

Contact information: Chancellor English 505-924-3325

[cenglish@cabq.gov](mailto:cenglish@cabq.gov)

*Chancellor English*