



Alan Varela, Director

Mayor Timothy M. Keller

January 5, 2024

Mathew Vallejos
Green Globe, LLC
PO Box 400
Los Lunas, NM 87031

Re: Netflix Expansion – Vendor Support 1 (Production Support Services Building)
Erosion and Sediment Control Plan
Engineer's Stamp Date 12/28/2023 (R16E3006AA)

Dear Mr. Vallejos,

Based upon the information provided in your submittal received 1/4/2024, the above referenced ESC Plan cannot be approved until the following comments are addressed.

1. The ESC Plan Map does not match the location marked on the Vicinity Map. Add a zone atlas map clearly indicating location and street names.
2. I can't tell the difference between building, sidewalk, asphalt, and dirt on the ESC Plan. These structures must be clearly identified in the SWPPP per CGP 7.2.4.b.vi. The same information is required in the ESC Application. You may attach a copy of the Site Plan to both the SWPPP and the ESC Application to address this requirement.
3. Update the engineer's stamp date each time the plan is changed.

If you have any questions, you can contact me at 924-3325 or cenglish@cabq.gov.

Sincerely,
Chancellor English

Chancellor English

Erosion and Sediment Control Specialist, Planning Dept.
Development and Review Services